

# Addendum No. 1

August 4, 2015

## Trumbull Public Works

### Renovations

**Bid # 6137**

## Trumbull, Connecticut

**Prepared by: DeCarlo & Doll, Inc.**

### Generator Installation at Trumbull Public Works - Bid # 6137

Prospective bidders and all concerned are hereby informed that the following changes are made as part of the Contract Documents and that they are notified to amend all documents accordingly and acknowledge receipt of this Addendum on the BID FORM of the Bid Proposal Package.

Addendum 1 consists of the following Heading Topic 'A' noted below. There is a total of 5 notes and clarifications written under the Heading below.

#### A. BID WALK THROUGH NOTES AND OTHER CLARIFICATIONS

1. Contract will be awarded based on BASE BID.
2. Generator is in Brewster, NY. Contractor is responsible for transport.
3. Contractor to include required shut-downs costs in their Bid. Shut-downs will have to occur after 3:30 PM or on Weekends. Contractor must provide the Town with a 48 hour notice prior to any shut-downs.
4. Concrete pad will be 4" minimum above adjacent asphalt paving.
5. Bid should be based on info contained in Bid Documents. Alternate wiring or piping methods will have to be reviewed and approved by Engineer prior to construction. Alternate methods may not be approved.

**End of Addendum No. 1**