

TOWN OF TRUMBULL, CONNECTICUT  
BOARD OF EDUCATION  
REQUEST FOR QUOTATION  
INSTALLATION OF ELECTRONIC SECURITY EQUIPMENT

BID 6161

DUE: January 26, 2016

**ADDENDUM #1**  
Amended 1-15-2016

This addendum #1 is for INSTALLATION OF ELECTRONIC SECURITY EQUIPMENT

Clarifying questions that were asked

- Agriscience 1<sup>st</sup> Floor
  - Alt Int. PTZ (Agsci C) – There is already an existing camera at this location- **This analog camera will be replaced with the camera specified and will not run through the analog/digital converter.**
- Jane Ryan School
  - Ext PTZ (JR-B) Outside 16B – Print says “Alternate”, Chart says “Base Bid” **This camera is an ALTERNATE item.**
- Madison Middle School
  - Ext PTZ (MAD-D) Outside 116 – Print says “Alternate”, Chart says “Base Bid” **This camera is an ALTERNATE item.**
- Middlebrook School
  - Ext PTZ (MB-D) Outside Custodial Office – Print says “Alternate”, Chart says “Base Bid” **This camera is an ALTERNATE item.**
- Hardware & Software
  - 11.1.1 states “Cameras will record @ 30FPS under normal conditions” **This is correct.**
  - Appendix A under IP Cameras states: FPS for all cameras to be set @ 8FPS **This is NOT correct.**
- Cabling
  - 5. Vendor must supply CAT6e patch cords: 100) 2’ & 100) 4’ pink & green, is this to replace existing patch cords? Will we be responsible for changing these out or just supplying the patch cords? **This applies only to cords installed with the cameras specified—not existing cords. There should not be any existing cords associated with the cameras as they are new equipment.**

- What time is the bid due on January 26<sup>th</sup>, 2016 & will there be a public opening?  
**2:00pm**

Proposal documents & Addendums can be accessed from the Town of Trumbull website ([www.trumbull-ct.gov](http://www.trumbull-ct.gov)) in the Purchasing Department Section - link to "Bid Invitations".

Inquiries of a technical nature may be directed to Steve Kennedy 203-452-4306