

TOWN OF TRUMBULL  
REQUEST FOR QUOTATION  
W.P.C.A. - EMERGENCY GENERATOR MAINTENANCE

GENERAL INSTRUCTIONS TO BIDDERS

BID NUMBER 6007      DUE: ~~SEPTEMBER 18, 2013~~ 3:00 PM  
DUE: SEPTEMBER 24, 2013      3:00 PM

**ADDENDUM 1**

ADDENDUM 1 is issued to add the following requirement to the SPECIFICATIONS AND REQUIREMENTS contained in the RFQ:

Drain all engine lube oil completely, refill engines with NEW manufacturers recommended type lube oil to correct level. Remove all filters on engine and replace with new filters including; lube oil, fuel oil, both primary and secondary, water and air filters. Remove and discard all waste oil and filters from job site properly.

NOTE: With this addendum the due date has been changed to **SEPTEMBER 24, 2013 at 3:00PM**

END OF ADDENDUM 1