

Town of Trumbull

CONNECTICUT



Trumbull Fire Marshal's
Office

Town Hall
5866 Main Street
Trumbull, Connecticut 06611
203-452-5080
Fax: 203-452-5093

firemarshal@trumbull-ct.gov

THE FOLLOWING IS A BASIC LIST OF ITEMS THAT WILL BE INSPECTED. OTHER VIOLATIONS MAY BE DISCOVERED DURING TIME OF INSPECTION.

FIRE ALARM AND SPRINKLER:

- Documentation showing fire alarm testing and servicing shall be provided. Fire alarm shall be maintained in accordance with NFPA 72
- Documentation showing sprinkler testing and servicing shall be provided. Sprinkler shall be tested in accordance with NFPA 25

EXIT SIGNS:

- All exit signs shall be properly illuminated
- All batteries for backup power shall be in proper working order

FIRE EXTINGUISHERS:

- All fire extinguishers shall have current year inspection tags
- All fire extinguishers shall be properly mounted
- All fire extinguishers shall be visually inspected and documented monthly

EMERGENCY LIGHTS:

- All emergency lights shall be in proper working order
- All emergency lights shall be tested once a month for 30 seconds and once a year for 1 ½ hours. Documentation shall be kept on this monthly testing

EXIT DOORS:

- All exit doors shall be kept clear
- All exit doors shall be closing and latching properly
- All exit doors shall be free of deadbolts, slide bolts and padlocks. Only one locking mechanism is permitted per door

STOCK/STORAGE:

- No storage or stock shall be stored within 18 inches of sprinkler heads

MISCELLANEOUS:

- The uses of extension cords are not permitted, however, power strips for the use of computers are allowed
- All electrical panels are to be labeled properly
- There shall be no storage within 36 inches of electrical panels or transformers

FOOD AND COOKING ESTABLISHMENTS:

- Provide documentation for semi annual hood and duct cleaning. Hood and duct maintenance shall be in accordance with NFPA 96
- Provide documentation that fire suppression system has been tested and serviced. Maintenance shall be in accordance with NFPA 17 & 17A