

**TOWN OF TRUMBULL
REQUEST FOR PROPOSALS
TOWN WIDE SANITARY SEWER REPAIRS**

**RFP: #6266
DUE: November 28, 2017 @ 2 pm**

Addendum #3 Dated 11-22-2017

This addendum is issued to clarify questions asked by potential bidders:

- 1) Do the items for manhole replacement, chimney replacement and point repair include temporary or permanent pavement repair?

These items are to include a temporary pavement repair as per SK-5 after the repair is made. These items are to include a permanent pavement repair after 5-6 months to allow for incidental settlement.

The cost of these items shall include saw cutting, excavation, disposal of waste material, resetting or replacement of brick course or rings, backfill, compaction, temporary and permanent pavement repair.

- 2) What is included in the item "Reset Manhole"?

The work under this item include the work required for resetting an existing manhole frame and cover. The cost of this item shall include saw cutting, excavation, disposal of waste material, resetting or replacement of brick course or rings, backfill, compaction, temporary and permanent pavement repair.

All technical inquiries regarding this request may be directed to Tighe & Bond, Consulting Engineers (203) 712-110 or Frank Smeriglio, Town of Trumbull, Engineering Department, (203) 452-5050 fsmeriglio@trumbull-ct.gov. All other questions shall be directed to Kevin Bova (203) 452-5042 Kbova@trumbull-ct.gov.