

**TOWN OF TRUMBULL
REQUEST FOR PROPOSAL**

**STROBEL ROAD RECONSTRUCTION PROJECT
LOTCIP NO. L144-0002**

**REBID-RFP: #6333
DUE: May 24, 2019 @ 2:00 PM**

Addendum #1 Dated May 20, 2019

Bidders are hereby informed that the Bidding Documents for the above-mentioned Project are modified, corrected, and/or supplemented as follows. Addendum No. 1 becomes part of the Bidding Documents and Contract Documents.

Acknowledge receipt of this addendum by inserting its number in the Bid Proposal form. Failure to acknowledge receipt of the Addendum may subject the Bidder to disqualification.

This addendum is issued for a clarification on the drawings.

Project Plan Changes

Sheet C8.1, 48" Precast Manhole

The manhole frame and cover shall be a Campbell Foundry Co. Pattern 1047 straight frame round cover with 26" diameter cover.

All technical inquiries regarding this request may be directed to Tighe & Bond, Consulting Engineers (203) 712-110 or William C. Maurer, Town of Trumbull, Engineering Department, (203) 452-5050 wmaurer@trumbull-ct.gov. All other questions shall be directed to Kevin Bova (203) 452-5042 Kbova@trumbull-ct.gov.