

**TOWN OF TRUMBULL, CONNECTICUT
BOARD OF EDUCATION
REQUEST FOR PROPOSAL
REMOVAL AND REPLACEMENT OF SIDEWALK AND CURBS
ON CALL UNIT PRICING**

BID NUMBER 6241: DUE: MAY 24, 2017 AT 2:00PM

Addendum #1

Posted on 5-2-2017

To clarify any misunderstandings on the specifications for concrete:

There is no Class D concrete; it is just going to be #4000 concrete

All other questions for this RFP may be directed to Mr. Kevin Bova, Purchasing Agent (203-452-5042) kbova@trumbull-ct.gov or Mark Deming BOE faculties' Director 203-452-4306
Deming, Mark <MDeming@trumbullps.org>