

**TOWN OF TRUMBULL  
ENGINEERING  
REQUEST FOR PROPOSALS  
RECONSTRUCTION OF MOOSE HILL ROAD**

**RFP #6296 DUE: August 24, 2018 at 2:00 PM**

Addendum #3 dated August 21, 2018

**LOT/CIP NO. L144-0001**

**BIDDER QUESTIONS WITH RESPONSES**

The following question was submitted by a bidder, response from the Town/Designer are in blue.

*In order to price Item #0100072A (Removal and Disposal of Underground Tanks) accurately, potential subcontractors are asking for the following information:*

- *How many (specs refer to LS, item is based on per each)?*

There is one tank within the project limits.

- *Sizes?*

For bidding purposes it shall be assumed that the underground tank is no greater than 2,000 gallons.

- *Product stored in tanks and estimated quantity left in tanks?*

There are approximately 100 gallons of #2 heating oil in the tank.

- *Any samples taken from soils around the tanks?*

There are no soil samples in the vicinity of the tank.

- *Fiberglass or steel construction?*

Tank construction is unknown.

- *Concrete slab on top or deadmen?*

Tank construction is unknown.

- *Does analytical data need to be supplied for backfill material?*

Backfill material shall meet the specification for borrow.